

ADDENDUM NO. 2
August 3, 2020
222380

RE: **TOWN OF MARLBOROUGH, NEW HAMPSHIRE**
WATER SYSTEM IMPROVEMENTS

FROM: DuBOIS & KING, INC.
P.O. Box 339
Randolph, Vermont 05060
(802) 728-3376

TO: **Prospective Bidders**

This Addendum forms part of the Contract Documents and modifies the original Bidding Documents issued by the Town of Marlborough, for the Water System Improvements project dated May 2020. **Acknowledge receipt of this Addendum in the space provided on Page 1 of the Bid Form. Failure to do so will subject the Bidder to disqualification.**

I. Pre-Bid Meeting

Not Applicable.

II. Contract Documents (Plan) Changes

On sheet C12, replace the two “8” TR FLEX RESTRAINED JOINT 45° BEND FITTING (OR APPROVED EQUAL)” callouts with “8” MJ EBAA IRON INC. RESTRAINED JOINT 45° BEND FITTING WITH MEGALUG (OR APPROVED EQUAL)”.

III. Contract Documents (Specifications) Changes

In technical specification section 02605, replace item 2.06.D. with “Restrained joint pipe shall be U.S. Pipe’s TR FLEX Pipe with polyurethane foam insulation and aluminum jack or approved equal. Restrained joint fittings shall be mechanical joint EBAA Iron Inc. restrained joint fittings with MEGALUG or approved equal.”

IV. Questions and Answers

Not Applicable.

V. Additional Information/Clarifications

Not Applicable.

This document constitutes Addendum 2 for this project.