

Town of Duxbury  
5421 VT Route 100  
Duxbury, Vermont 05676

**ADDENDUM NO. 2**  
Scrabble Hill Road Culvert Replacement  
May 28, 2021

**TO: Prospective Bidders**

This Addendum forms part of the Contract Documents and modifies the original Bidding Documents issued by the Town of Duxbury, Vermont for the Culvert Replacement Project. **Please acknowledge receipt of this Addendum in the proposal. Failure to do so may subject the Bidder to disqualification.**

I. **Contract Documents: Specification Changes**

None at the time of issuance of this Addendum.

II. **Contract Documents: Plan Changes**

None at the time of issuance of this Addendum.

III. **Questions and Answers:**

1. Are there any weight limits for the roadway?

The posted limits are for mud season. There are no known restrictions beyond the normal State restrictions.

2. Were there ledge probes?

Probe locations and depths are shown on the site plans. The existing 4' diameter, temporary culvert was installed two years ago when the CMP washed out. No ledge was removed as part of that installation, but there was refusal as indicated in the plans when probes were completed.

3. Are there overhead wires in the way?

There are overhead electrical wires on the eastern side of Scrabble Hill Rd which are not shown on the plans. Coordination with the utility companies will need to be completed if disturbance of the services is necessary.

End of Addendum #2