

**ADDENDUM NO. 2**

March 27, 2023

227991

**RE:           WHOLE VILLAGE FAMILY RESOURCE CENTER  
              PARKING LOT REPLACEMENT**

**FROM:       DuBOIS & KING, INC.**  
              36 Penn Plaza  
              Bangor, Maine 04401  
              (207) 573-4130

**TO:           Prospective Bidders**

This Addendum forms part of the Contract Documents and modifies the original Bidding Documents issued by the Whole Village Family Resource Center for the Parking Lot Replacement project dated March, 2023. **Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so will subject the Bidder to disqualification.**

**I. Contract Documents (Plan) Changes**

1. None

**II. Contract Documents (Specification) Changes**

1. None

**III. Clarifications**

**1. Asphalt Sidewalk Section.**

Asphalt sidewalk section shall consist of 1.5” thick layer of compacted wearing course (1/2”) over 1.5” thick layer of compacted binder course (3/4”) over 12” thick layer of compacted base aggregate (NHDOT 304.4).

**IV. Additional Information**

1. None

**This document constitutes Addendum 2 for this project.**